

POPSF 11.3.40.1 v.1
8/15/08

A

USEPA SF



1445036



CITY OF PORTLAND ENVIRONMENTAL SERVICES



1211 S.W. 5th Ave., Suite 800, Portland, Oregon 97204-3713
(503) 823-5320, FAX (503) 823-5559

5-23-95

Forest Lane
Lakeside Industries
P.O. Box 1379
Bellevue, WA 98009

RE: Stormwater inspection of,

Lakeside Industries
4850 NW Front Ave.
Portland, OR 97210

Dear Mr. Lane

This letter is to follow up on the stormwater inspection of 5-4-95 and the subsequent dye testing of the oil water separator. The diesel tank containment drains to the oil water separator. The flow from the separator was not observed in the city storm sewer so it is assumed that the separator drains to a dry well. It does not appear that Lakeside Industries is required to apply for a stormwater permit at this time. If you have any questions please call me at 823-7885.

Sincerely

John Holtrop
Industrial Stormwater Section

CC: Paul Keiran